



**SECTION A-A**

**PLAN VIEW**

- NOTES:
1. 4,000 PSI CONCRETE AT 28 DAYS.
  2. REINFORCEMENT BARS PER ASTM A-615, GRADE 60 WELDED WIRE FABRIC PER ASTM A-185, GRADE 70
  3. ANY ALTERATION TO THIS DRAWING MUST BE SUBMITTED TO GSP IN WRITING PRIOR TO PRODUCTION.

SHEET  
**1**  
OF  
**1**

WEIGHT  
8" PAD=3,100 LBS  
LIFTING  
(4) 5" UTILITY ANCHORS

PRECAST TYPE II-A  
TRANSFORMERPAD  
74" x 70" x 8"  
W085015 DG-12-785-3

GARDEN STATE PRECAST  
FARMINGDALE, N.J.  
PHONE #: 732-938-4436 FAX #: 732-938-6069