



PLAN VIEW



SECTION A-A



SECTION B-B

NOTES.

1. 4000 PSI CONCRETE AT 28 DAYS.
2. DESIGN PER ASTM C-913, LATEST REVISION.
3. ANY ALTERATION TO THIS DRAWING MUST BE SUBMITTED TO GSP IN WRITING PRIOR TO PRODUCTION
4. DESIGNED FOR USE IN LIGHT TRAFFIC AREAS

SHEET  
1 OF  
1

WEIGHT:  
28" BASE = 3,050 LBS  
LIFTING:  
(4) 5" UTILITY ANCHORS

PSE&G  
28"x30"x28"  
PRECAST HANDHOLE

GARDEN STATE PRECAST  
FARMINGDALE, N.J.  
PHONE #: 732-938-4436 FAX #: 732-938-7096